

# LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS  
207 SE DOUGLAS STREET  
LEE'S SUMMIT, MISSOURI 64063-2372  
(816) 969-1300  
FAX (816) 969-1313  
TDD (816) 969-7407

## PLAN REVIEW CONDITIONS

August 11, 2011

HOLLIS & MILLER GROUP INC  
220 NW EXECUTIVE WAY  
LEES SUMMIT MO, MO 64063

Permit No: PRCOM20114294  
Project Title: REJUVENATE  
Project Address: 400 SW LONGVIEW BLVD, Unit:160, LEES SUMMIT, MO 64081  
Parcel Number: 62420150101000000  
Location: TOWER PARK COMMERCIAL-PHASE 2---PT LOT 3 DAF: BEG NW COR SD LOT TH N 47 DEG 47 MIN 39 SEC 21.38' TH NELY ALG CURV LF RAD 340' DIST 191.77' TH N 58 DEG 46 MIN 33 SEC E 74.75' TH S 76 DEG 13 MIN 27 SEC E 63.64' TH S 31 DEG 13 MIN 27 SEC E 185.25' TH S 58 DEG 46 MIN 33 SEC W 157' MOL TH N 63 DEG 48 MIN 07 SEC W 146' MOL TH N 86 DEG 44 MIN 52 SEC W 172.98' TH N 03 DEG 15 MIN 08 SEC E 97.29' TO POB  
Type of Work: Alter Commercial  
Occupancy Group: BUSINESS  
Description: REJUVENATE TENANT EXPANSION

***The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.***

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

### **Fire Plan Review**

**Reviewed By: Jim Eden**

**Approved**

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Action required: Provide shop drawings for sprinkler and alarm system alterations.

2. 2006 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Action required: Provide an additional minimum 2A:10B:C fire extinguisher to maintain 75 foot travel distance. Verified at inspection.

3. 2006 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible

from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

Action required: All exterior doors shall have the same suite number posted on them. Verified at inspection.

**Building Plan Review**

**Reviewed By: Michael Weisenborn**

**Pending**

***The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.***

***The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.***