LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS 207 SE DOUGLAS STREET LEE'S SUMMIT, MISSOURI 64063-2372 (816) 969-1309 FAX (816) 969-1313 TDD (816) 969-7407

PLANS REVIEW CONDITIONS

Permit No: PRCOM20116313 Project Title: Location: 460 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081 Type of Work: Occupancy Group: R-2 Description: SPRINKLER SYSTEM ALTERATIONS FOR THE ENTIRE COMPLEXE Construction Type: Type VB (Unprotected) Map Page: Date: December 14, 2011 Applicant:

American Fire Sprinklers, LLC 10987 Lin Valle Drive, P.O Box 20127 St. Louis, MO

<NO CONTACT NAME AVAILABLE> <NO CONTACT INFORMATION AVAILABLE>

Primary: <NO PRIMARY PHONE>

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Jim Eden

Released for Construction

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Alteration plans for Buildings A-J on 12/1/2011.

2. Design criteria shall be to the 2002 Edition of NFPA 13.

For information only.

3. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule an inspection.

4. Impairment of the system shall be kept to a minimum. Notify Fire Communications at (816) 969-7407 when systems go out of service and when they are restored.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.