

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLAN REVIEW CONDITIONS

December 18, 2012

SCHARHAG ARCHITECTS
310 ARMOUR RD #218A
NORTH KANSAS CITY, MO 64116
CHAPEL RIDGE RETAIL LLC
3170 NE CARNEGIE DR # 400
LEES SUMMIT, MO 64064--3215

Permit No: PRCOM20122713
Project Title: LIFE TRANSFORMATIONS FITNESS CENTER
Project Address: 3680 NE AKIN DR, Unit:130, LEES SUMMIT, MO 64064
Parcel Number: 43810020700000000
Location: CHAPEL RIDGE BUSINESS PARK, LOTS 10-18 & TRACTS H THRU K---LOT 17
Type of Work: NEW TENANT FINISH
Occupancy Group: ASSEMBLY FOR INDOOR SPORTING INCL ARENAS, RINKS, COURTS, SWIMMING POOLS
Description: TENANT FINISH FOR FITNESS CENTER

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Michael Weisenborn

Pending

Fire Plan Review

Reviewed By: Brian Austerman

Approved with Conditions

1. 2006 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

Address all exterior doors for the space including suite number if applicable. Verified at inspection

2. 2006 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Provide a minimum of 3 2A10B:C Fire Extinguishers, verified at inspection

3. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Provide plans for alterations to the sprinkler system for approval

4. 2006 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Provide plans for the alarm system modifications for approval

5. 2006 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

The sprinkler system shall have current inspection at time of final inspection

6. 1006.3 Illumination emergency power.

The power supply for means of egress illumination shall normally be provided by the premises' electrical supply.

In the event of power supply failure, an emergency electrical system shall automatically illuminate the following areas:

1. Aisles and unenclosed egress stairways in rooms and spaces that require two or more means of egress.
2. Corridors, exit enclosures and exit passageways in buildings required to have two or more exits.
3. Exterior egress components at other than the level of exit discharge until exit discharge is accomplished for buildings required to have two or more exits.
4. Interior exit discharge elements, as permitted in Section 1024.1, in buildings required to have two or more exits.
5. Exterior landings, as required by Section 1008.1.5, for exit discharge doorways in buildings required to have two or more exits.

Provide exterior egress illumination if not already existing

7. 504.2 Maintenance of exterior doors and openings.

Exterior doors and their function shall not be eliminated without prior approval. Exterior doors that have been rendered nonfunctional and that retain a functional door exterior appearance shall have a sign affixed to the exterior side of the door with the words THIS DOOR BLOCKED. The sign shall consist of letters having a principal stroke of not less than 0.75 inch (19.1 mm) wide and at least 6 inches (152 mm) high on a contrasting background. Required fire department access doors shall not be obstructed or eliminated. Exit and exit access doors shall comply with Chapter 10. Access doors for high-piled combustible storage shall comply with Section 2306.6.1.

Label exterior of door indicating the door is blocked, verified at inspection

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.