

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLAN REVIEW CONDITIONS

April 11, 2013

JEFFREY E SMITH INV CO LC
PO BOX 7688
COLUMBIA, MO 65205
ROSEMANN & ASSOCIATES, PC
1526 GRAND BLVD
KANSAS CITY, MO 64108

Permit No: PRCOM20130422
Project Title: WILSHIRE HILLS II
Project Address: 3360 NE WILSHIRE DR, LEES SUMMIT, MO 64064
Parcel Number: 43830990700000000
Location: WILSHIRE HILLS 2ND PLAT LOTS 3 AND 4 & TRACT B---LOT 3
Type of Work: NEW MULTI-FAMILY
Occupancy Group: RESIDENTIAL, MULTI-FAMILY
Description: 3-STORY SENIOR LIVING

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Michael Weisenborn

Pending

1. The project cost, which is used to establish the permit fee, has not been provided.

Action required - Provide the project cost.

2. The size of the water meter to be used is not indicated on the plans.

Action required - Provide additional information.

3. 2006 IBC 1704.1.1 - Statement of special inspections. The permit applicant shall submit a statement of special inspections prepared by the registered design professional in responsible charge in accordance with 106.1 as a condition for permit issuance. This statement shall be in accordance with Section 1705.

Exceptions: 1. A statement of special inspections is not required for structures designed and constructed in accordance with the conventional construction provisions of Section 2308. 2. The statement of special inspections is permitted to be prepared by a qualified person approved by the building official for construction not designed by a registered design professional.

Action required - Provide a statement of special inspections for this project. The letter needs to be from the company hired to perform the special inspections.

4. 2006 IBC 1704.1.2 - Report Requirement. Special inspectors shall keep records of inspections. The special inspector shall furnish inspection reports to the building official, and to the registered design professional in responsible charge. Reports shall indicate that work inspected was done in conformance to approved construction documents. Discrepancies shall be brought to the immediate attention of the contractor for correction. If the discrepancies are not corrected, the discrepancies shall be brought to the attention of the building official and to the registered design professional in responsible charge prior to the completion of that phase of the work. A final report documenting required special inspections and correction of any discrepancies noted in the inspections shall be submitted at a point in time agreed upon by the permit applicant and the building official prior to the start of work.

Action required - This comment is for information purposes.

5. This structure has been assigned one address. All suites/apartments shall be assigned an address by the owner which can be numeric, alphabetic or a combination of both. If the building has multiple stories the suite/apartment number shall start with a number representing the floor on which the unit is located.

Action required - Provide an address layout for the apartments. We request that the addressing start on the west end of the building and continue through the common areas to the north end of the building. The first part of the unit identifier should be numerical and identify the floor level. The rest can be your choice.

6. The actual stair drawings are not showing up for Details A2, B2 and C2 on Sheet A-3.4.

Action required - Make needed corrections.

7. Copies of the engineered truss package were not provided at the time of permit application.

Fire Plan Review

Reviewed By: Brian Austerman

Rejected

1. 2006 IFC 506.1- Where required. Where access to or within a structure or an area is restricted because of secured openings or where immediate access is necessary for life-saving or fire-fighting purposes, the fire code official is authorized to require a key box to be installed in an approved location. The key box shall be of an approved type and shall contain keys to gain necessary access as required by the fire code official.

Knox box will be required for access to sprinkler room and also for the elevator. Call (816) 969-1300 to obtain knox box applications.

2. 1020.1.6 Stairway floor number signs.

A sign shall be provided at each floor landing in interior exit enclosures connecting more than three stories designating the floor level, the terminus of the top and bottom of the stair enclosure and the identification of the stair. The signage shall also state the story of, and the direction to the exit discharge and the availability of roof access from the stairway for the fire department. The sign shall be located 5 feet (1524 mm) above the floor landing in a position that is readily visible when the doors are in the open and closed positions.

Stairway doors shall be marked for each floor, verified at inspection

3. Section 905.3.1 is amended to read as follows:

905.3.1 Building height. Class 1 standpipe systems shall be installed throughout buildings where the floor level of the highest story is located more than two stories above the lowest level of the fire department vehicle access, or where the floor level of the lowest story is located more than two stories below the highest level of fire department vehicle access.

Standpipes will be required, to be included in sprinkler plan submittal

4. Relocate hydrant that serves the FDC to the building side of the drive. In its current position when utilizing this hydrant it would block access the the remainder of that side of the building for other FD apparatus

5. D105.2 Width.

Fire apparatus access roads shall have a minimum unobstructed width of 26 feet (7925 mm) in the immediate vicinity of any building or portion of building more than 30 feet (9144 mm) in height.

Access roads shall have a minimum width of 26' Plans reflect 24' access into the parking areas and 20' on the north access road.

6. NFPA 13R 2002 ed. 6.6.6 Sprinklers shall not be required in attics, penthouse equipment rooms, elevator machine rooms, concealed spaces dedicated exclusively to and containing only dwelling unit ventilation equipment, crawl spaces, floor/ceiling spaces, noncombustible elevator shafts where the elevator cars comply with ANSI A17.1....

Confirm the rating of the elevator shaft and elevator car compliance.

7. NFPA 13R 6.6.2 Sprinklers shall not be required in bathrooms where the bathroom area does not exceed 55ft²

Bathrooms exceeding 55 sq/ft shall have sprinkler protection

8. NFPA 13R 2002 ed. 6.6.3 Except where specified in 6.6.4 sprinklers shall not be required in clothes closets, linen closets, and pantries within dwelling units that meet all of the following conditions:

(1) The area of the space does not exceed 24 sq/ft

(2) The least dimension does not exceeds 3 ft

(3) The walls and ceilings are surfaces with noncombustible or limited combustible materials as defined by NFPA 220.

For information only

9. 2006 IFC 609.2- Where required. A Type I hood shall be installed at or above all commercial cooking appliances and domestic cooking appliances used for commercial purposes that produce grease vapors.

Provide a letter stating the use of the communal kitchen. Is this to be used for food preparation or rewarmed?

10. 2006 IFC 1004.3- Posting of occupant load. Every room or space that is an assembly occupancy shall have the occupant load of the room or space posted in a conspicuous place, near the main exit or exit access doorway from the room or space. Posted signs shall be of an approved legible permanent design and shall be maintained by the owner or authorized agent.

Assembly areas occupancy shall be posted

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.

