

CITY OF LEE'S SUMMIT

CODES ADMINISTRATION DEPARTMENT

220 SE Green Street

Lee's Summit, MO 64063

(816) 969-1200

Fax (816) 969-1201

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20100049	Date:	November 16, 2010
Project Title:	Saint Luke's Surgical Center	Applicant:	
Project Address:	120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086		ACI BOLAND
Location:	SAINT LUKE'S HOSPITAL OF LEE'S SUMMIT LOT 1---LOT 1 (EX PT IN RD)		11229 NALL SUITE 140 LEAWOOD KS, KS 66211
Type of Work:	Alter Commercial		
Occupancy Group:	Institutional, incapacitated		
Description:	Convert storage room into office and consultation room		

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review

Reviewed By: Jim Eden

Approved

1. Fire Department - 2006 IFC 901.4.1 Required fire protection systems.
Fire protection systems required by this code or the International Building Code shall be installed, repaired, operated, tested and maintained in accordance with this code.

For information only, provide shop drawings for any system alteration.,

Building Plan Review

Reviewed By: Michael Weisenborn

Pending

- _____ Approved to issue per the listed conditions.
- _____ Do not issue per the listed conditions.
- _____ Approved to construct foundation only per the listed conditions.
- _____ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

Signature of Applicant

Date

Print Applicant Name

CompanyName

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.