

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLAN REVIEW CONDITIONS

May 29, 2013

TURNER CONSTRUCTION CO
2345 GRAND BOULEVARD SUITE 1000
KANSAS CITY, MO 64108

Permit No: PRCOM20130791
Project Title: SAINT LUKES HOSPITAL INNER LOOP PARKING RECONFIGURATION
Project Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086
Parcel Number: 52400044000000000
Location:
Type of Work: ALTERATION OTHER COM
Occupancy Group: UNCLASSIFIED
Description: PARKING LOT LIGHTING AND RETAINING WALL

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Michael Weisenborn

Approved

2. 2006 IBC 1704.1.2 - Report Requirement. Special inspectors shall keep records of inspections. The special inspector shall furnish inspection reports to the building official, and to the registered design professional in responsible charge. Reports shall indicate that work inspected was done in conformance to approved construction documents. Discrepancies shall be brought to the immediate attention of the contractor for correction. If the discrepancies are not corrected, the discrepancies shall be brought to the attention of the building official and to the registered design professional in responsible charge prior to the completion of that phase of the work. A final report documenting required special inspections and correction of any discrepancies noted in the inspections shall be submitted at a point in time agreed upon by the permit applicant and the building official prior to the start of work.

Action required - This comment is for information purposes.

Fire Plan Review

Reviewed By: Jim Eden

Approved

Fire Plan Review

Reviewed By: Brian Austerman

Approved

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.