



LEE'S SUMMIT, MISSOURI FIRE DEPARTMENT LOSS REDUCTION PROGRAM



NOTIFICATIONS/CONTACT INFORMATION SECTION

PAGE 1

☐ CHANGES

BUSINESS NAME	Glo Nail Lounge		
ADDRESS	930 NW BLUE PKWY, Unit:P, LEES SUMMIT, MO 64086		
OWNER/OPERATOR NAME	ANS CONSTRUCTION:	TELEPHONE	(816) 231-2288
ADDRESS	29 W 14TH AVENUE KANSAS CITY, MO 64116-3923 Primary: (816) 231-2288 Cell: (816) 210-1226		

EMERGENCY CONTACT INFORMATION

NAME	TELEPHONE
1.	
2.	
3.	
4.	

LOSS REDUCTION TYPE

<input type="checkbox"/> Occupancy	<input type="checkbox"/> Semi-Annual	<input type="checkbox"/> Annual	<input type="checkbox"/> Life Safety	<input type="checkbox"/> Sprinkler	<input type="checkbox"/> Hazardous Material Permit
<input type="checkbox"/> Complaint	<input type="checkbox"/> Explosive Storage	<input type="checkbox"/> UST	<input type="checkbox"/> Post-Incident	<input type="checkbox"/> Open Burning	<input type="checkbox"/> Other
CLASS: B	Map#: 195A	PFA#:	KNOX BOX:	KNOX LOCATION:	PERMIT #

LOSS REDUCTION NARRATIVE

☐ NO CORRECTIONS NOTED

☐ ALL CORRECTIONS COMPLETED

Last Inspection

1st Inspection

2nd Inspection

3rd Inspection

4th Inspection

INSPECTION	INSPECTOR	OUTCOME	DATE
Alarm Test	Joe Dir	Passed	Thursday, March 17, 2011
Sprinkler - Hydrostatic Test		Not Required	Monday, March 14, 2011
Sprinkler - Flow Test	Joe Dir	Passed	Wednesday, March 16, 2011
Occupancy Inspection - Fire	Joe Dir	Temporary C of O	Wednesday, March 16, 2011
Corrective Action Required: 1 New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In multi-tenant			

commercial buildings where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm). 6" MINIMUM WHITE NUMBERS FOR THE FRONT, 4" MINIMUM BLACK NUMBERS FOR THE REAR DOOR

Corrective Action Required:

- 2 LABEL THE SPRINKLER SYSTEM VALVES WITH THE SUITE ADDRESS OF 930-P, FLOW ALARM AND THE TAMPER SWITCH.

Corrective Action Required:

- 3 Portable fire extinguishers shall be installed in the following locations. 1. In new and existing Group A, B, E, F, H, I, M, R-1, R-2, R-4 and S occupancies. Exception: In new and existing Group A, B and E occupancies equipped throughout with quick-response sprinklers, portable fire extinguishers shall be required only in locations specified in Items 2 through 6.2. Within 30 feet (9144 mm) of commercial cooking equipment. 3. In areas where flammable or combustible liquids are stored, used or dispensed. 4. On each floor of structures under construction, except Group R-3 occupancies, in accordance with Section 1415.1.5. Where required by the sections indicated in Table 906.1.6. Special-hazard areas, including but not limited to laboratories, computer rooms and generator rooms, where required by the fire code official.

Portable fire extinguishers shall be installed in the following locations. 1. In new and existing Group A, B, E, F, H, I, M, R-1, R-2, R-4 and S occupancies. Exception: In new and existing Group A, B and E occupancies equipped throughout with quick-response sprinklers, portable fire extinguishers shall be required only in locations specified in Items 2 through 6.2. Within 30 feet (9144 mm) of commercial cooking equipment. 3. In areas where flammable or combustible liquids are stored, used or dispensed. 4. On each floor of structures under construction, except Group R-3 occupancies, in accordance with Section 1415.1.5. Where required by the sections indicated in Table 906.1.6. Special-hazard areas, including but not limited to laboratories, computer rooms and generator rooms, where required by the fire code official. PROVIDE 1 MINIMUM SIZE 2A-10BC EXTINGUISHER, MOUNT ON THE WALL CLOSE TO AN EXIT WITH THE TOP NO HIGHER THAN 60" OFF THE FLOOR.

Corrective Action Required:

- 4 Every room or space that is an assembly occupancy shall have the occupant load of the room or space posted in a conspicuous place, near the main exit or exit access doorway from the room or space. Posted signs shall be of an approved legible permanent design and shall be maintained by the owner or authorized agent. POST AN OCCUPANT LOAD OF 50 TOWARDS THE FRONT OF THE STORE.

Occupancy Inspection - Fire

Joe Dir

Passed

Friday, March 18, 2011

Corrective Action Required:

- 1 New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In multi-tenant commercial buildings where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm). 6" MINIMUM WHITE NUMBERS FOR THE FRONT, 4" MINIMUM BLACK NUMBERS FOR THE REAR DOOR

Corrective Action Required:

- 2 LABEL THE SPRINKLER SYSTEM VALVES WITH THE SUITE ADDRESS OF 930-P, FLOW ALARM AND THE TAMPER SWITCH.

Corrective Action Required:

- 3 Portable fire extinguishers shall be installed in the following locations. 1. In new and existing Group A, B, E, F, H, I, M, R-1, R-2, R-4 and S occupancies. Exception: In new and existing Group A, B and E occupancies equipped throughout with quick-response sprinklers, portable fire extinguishers shall be required only in locations specified in Items 2 through 6.2. Within 30 feet (9144 mm) of commercial cooking equipment. 3. In areas where flammable or combustible liquids are stored, used or dispensed. 4. On each floor of structures under construction, except Group R-3 occupancies, in accordance with Section 1415.1.5. Where required by the sections indicated in Table 906.1.6.

Special-hazard areas, including but not limited to laboratories, computer rooms and generator rooms, where required by the fire code official.

Portable fire extinguishers shall be installed in the following locations.1. In new and existing Group A, B, E, F, H, I , M, R-1, R-2, R-4 and S occupancies.Exception: In new and existing Group A, B and E occupancies equipped throughout with quick- response sprinklers, portable fire extinguishers shall be required only in locations specified in Items 2 through 6.2. Within 30 feet (9144 mm) of commercial cooking equipment.3. In areas where flammable or combustible liquids are stored, used or dispensed.4. On each floor of structures under construction, except Group R-3 occupancies, in accordance with Section 1415.1.5. Where required by the sections indicated in Table 906.1.6. Special-hazard areas, including but not limited to laboratories, computer rooms and generator rooms, where required by the fire code official. PROVIDE 1 MINIMUM SIZE 2A-10BC EXTINGUISHER, MOUNT ON THE WALL CLOSE TO AN EXIT WITH THE TOP NO HIGHER THAN 60" OFF THE FLOOR.

Corrective Action Required:

4 Every room or space that is an assembly occupancy shall have the occupant load of the room or space posted in a conspicuous place, near the main exit or exit access doorway from the room or space. Posted signs shall be of an approved legible permanent design and shall be maintained by the owner or authorized agent. POST AN OCCUPANY LOAD OF 50 TOWARDS THE FRONT OF THE STORE.

DATE OF REPORT	INSPECTOR	PREVENTION FOLLOW-UP REQUIRED?	RESPONSIBLE SIGNATURE
March 18, 2011	Joe Dir	<input type="checkbox"/> Yes <input type="checkbox"/> No	