

# LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS  
207 SE DOUGLAS STREET  
LEE'S SUMMIT, MISSOURI 64063-2372  
(816) 969-1300  
FAX (816) 969-1313  
TDD (816) 969-7407

## PLAN REVIEW CONDITIONS

April 23, 2013

STUCKER CONSTRUCTION INC  
103 SE MAGELLAN DR  
BLUE SPRINGS, MO 64014  
SOUTHSIDE PLAZA LLC  
215 W 77TH ST  
KANSAS CITY, MO 64114

Permit No: PRCOM20130560  
Project Title: GOLDEN PAWS GROOMING  
Project Address: 848 SW BLUE PKWY, LEES SUMMIT, MO 64063  
Parcel Number: 61420023800000000  
Location: SEC 7 TWP 47 RNG 31 PT OF N 1/2 NW 1/4 DAF: BEG ON W LI NICHOLS ST AT A PT  
250' S OF S LI 3RD ST TH S 289.2' TH W 226.2' TH S 175' TO NLY LI HWY 50 TH  
NWLY ALG SD LI 459.6' TH N 215' MOL TH E 1212.26'  
Type of Work: CHANGE OF TENANT  
Occupancy Group: BUSINESS  
Description: TENANT FINISH

***The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.***

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

### **Fire Plan Review**

**Reviewed By: Brian Austerman**

**Approved with Conditions**

1. 1011.1 Where required.

Exits and exit access doors shall be marked by an approved exit sign readily visible from any direction of egress travel. Access to exits shall be marked by readily visible exit signs in cases where the exit or the path of egress travel is not immediately visible to the occupants. Exit sign placement shall be such that no point in a corridor is more than 100 feet (30 480 mm) or the listed viewing distance for the sign, whichever is less, from the nearest visible exit sign.

Action Required: Provide an exit sign over the door in the daycare room that leads to the Customer Service Area.

On the resub an exit sign was added near the washing room, relocate this to the door leading out of the daycare into the customer service area.

2. 2006 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible

from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

Provide addressing on front and rear doors, if not existing

3. 2006 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Provide a minimum of one 2A10B:C Extinguisher, verified at inspection

***The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.***

***The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.***