



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRRES20130212, Building Permit - Residential
Address: 3201 SE 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Friday, June 28, 2013

Corrective Action Required
1 MISC

-REPAIR STRUCTURAL STRAP CUT FOR HVAC AT FIRST FLOOR
-FIREBLOCK HVAC CHASE FIRST FLOOR
-INSTALL FIREPLACE FRAMING *SECURE FIREPLACE TO FRAME

*OK TO INSUALTE. NO ROCK

Comments: