



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130263, Building Permit - Commercial
Address: 950 NW BLUE PKWY, Unit:B, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Partial	Friday, June 28, 2013

Corrective Action Required

1	MISC	IN-USE COVER REQUIRED AT RTU ELECT RECEPT
---	------	---

Comments:

Frank,

When we spoke yesterday I did not remember Mike had a few outstanding issues (beside the lighted sign installation) when I issued the TCO. I received your email message with attached photos of the signs, and I have eliminated that item. Of Mike's four issues I found three (water heater expansion tank, slipsheets at rooftop gas piping support blocks, rooftop cleaning) completed. However, the electrical receptacle at the RTU still needs an in-use cover. Please have someone call it in for re-inspection when completed.

John