



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20131076, Building Permit - Commercial
Address: 3680 NE AKIN DR, Unit:140, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	Khanh Nguyen	Passed	Tuesday, July 02, 2013

In-wall Inspection	Khanh Nguyen	Failed	Tuesday, July 02, 2013
---------------------------	--------------	--------	------------------------

Corrective Action Required

1	MISC	-PROTECT PLUMBING WHERE INSTALLED WITHIN 1.5" OF STUD/TRACK SURFACE
---	------	--

Comments:

OK TO RELEASE METER TO PANEL 138