



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20131076, Building Permit - Commercial  
Address: 3680 NE AKIN DR, Unit:140, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Khanh Nguyen	Failed	Wednesday, July 03, 2013

### Corrective Action Required

1	MISC	-PROTECT PLUMBING WHERE INSTALLED WITHIN 1.5" OF STUD/TRACK SURFACE
---	------	---------------------------------------------------------------------

### Comments:

DO NOT ROCK THE WALLS OF BREAK AND MOP SINK RMS