S LEE'S SUMMIT M I S S O U R I

CODES ADMINISTRATION

PLAN REVIEW CONDITIONS

July 08, 2013

DEV INC. 9401 W 87TH ST, SUITE 215 OVERLAND PARK, KS 66212

Permit No:	PRCOM20131297
Project Title:	RABO AGRIFINANCE
Project Address:	5008 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064
Parcel Number:	43240080600000000
Location:	EXECUTIVE LAKES CENTER LOTS 11B & 11CLOT 11B
Type of Work:	NEW TENANT FINISH
Occupancy Group:	BUSINESS
Description:	TENANT FINISH

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200		Fire Department (816) 969-1300			
Licensed Contractors		Reviewed By: Michael Weisenbo	'n	Approved	
Building Plan Review		Reviewed By: Michael Weisenbo	'n	Approved	
Fire Plan Review		Reviewed By: Brian Austerman		Approved with Conditions	

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Provide sprinkler plans for approval if modifications are made

2. 2006 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. .A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Provide alarm plans for approval if modifications are made to the alarm system

3. 2006 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

220 SE Green Street | Lee's Summit, MO 64063 | 816.969.1200 | cityofLS.net/Development

Provide a 2A10B:C extinguisher for ecvery 3,000 sq/ft

Location shown on resub

- _____ Approved to issue per the listed conditions.
- _____ Do not issue per the listed conditions.
- _____ Approved to construct foundation only per the listed conditions.
- _____ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

Signature of Applicant	Date	
Print Applicant Name	CompanyName	

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.