



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130506, Building Permit - Commercial
Address: 310 SW WARD RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Hood/Duct Inspection	Mark Harding	Partial	Wednesday, July 10, 2013

Corrective Action Required
1 MISC

WELDS OK TO COVER -WILL SCHEDULE FOR FIRE WRAP MONDAY

All Rough Inspection - Commercial	Mark Harding	Partial	Wednesday, July 10, 2013
--	--------------	---------	--------------------------

Corrective Action Required
1 MISC

12' WALL BUILT WEST SIDE OF BAKERY- NO INSPECTION ON WALL BEFORE IT WAS ROCKED- NO ELECTRICAL OR PLUMBING IN WALL.

2. WALL AT CHEF GRILL- WILL SCHEDULE WHEN TRADES ARE READY.

Underslab Plumbing Inspection - Commercial	Mark Harding	Passed	Wednesday, July 10, 2013
---	--------------	--------	--------------------------

Comments:

