



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20130506, Building Permit - Commercial  
Address: 310 SW WARD RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Mark Harding	Failed	Thursday, July 11, 2013

Corrective Action Required

1 MISC

BOND METAL BOX COOLER WALL. OK TO COVER  
CHEF WALL NEEDS PROTECTION PLATES FOR PLUMBING

**Comments:**