



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121010, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Monday, July 15, 2013
Partial Correction 1 MISC		1ST AND 2ND LAYER AT SOFFIT FROM 8 TO 9 LINE APPROVED	
Partial Correction 2 MISC		OK TO COVER WHEN READY FIRE-BLOCKING OF WALL/FLOOR INTERSECTION AT EAST EXTERIOR ARC WALL BETWEEN COLUMN LINES (7) AND (12.9);	
Partial Correction 3 MISC		OK TO COVER WHEN READY 2ND LAYER 5/8" TYPE X GWB AT WALL ON (19) FROM (C') TO (D') AT 5TH FLOOR. TAPE, MUD & FIRE-SEAL YET TO BE COMPLETED & APPROVED.	
Partial Correction 4 MISC		OK TO COVER WHEN READY FOLLOWING COMPONENTS OF RATED WALLS OF MECHANICAL SHAFT AT 5TH FLR: FRAMING + SHAFT LINER ;	

Comments: