



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O. BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRRES20131204, Building Permit - Residential  
Address: 1400 SE RANSON RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mike Copeland	Failed	Monday, July 15, 2013

Partial Correction  
1 MISC

-GARAGE AND PORCH ONLY INSPECED:  
INSTALL 1000 LB STRAPS PER DETAIL ON EACH SIDE OF EACH GARAGE OVERHEAD DOOR.

**Comments:**