



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20121010, Building Permit - Commercial  
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Thursday, July 18, 2013

Partial Correction  
4 MISC

OK TO COVER WHEN READY FOLLOWING COMPONENTS OF RATED WALLS OF MECHANICAL SHAFT AT 5TH FLR: FRAMING + SHAFT LINER ; **ONE LAYER 5/8" TYPE X GWB;**

**Comments:**