

CITY OF LEE'S SUMMIT CODES ADMINISTRATION 220 SE GREEN ST. P.O.BOX 1600

PHONE: 816-969-1200

FAX:

816-969-1201

Inspection Summary

Permit #: PRCOM20131601, Building Permit - Commercial Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Underground John Borns Passed Thursday, July 25, 2013

Plumbing Inspection

- Commercial

Comments: PEX WATER LINE SLEEVED IN PVC PIPE IN 32" (PLUS 10" BASE + PAVEMENT) TRENCH FROM W END OF PARKING LOT TO NEAR EAST END. NO ISSUES FOUND. OK TO COVER WHEN READY.