



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20131297, Building Permit - Commercial
Address: 5008 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|-------------------------------------|--------------|----------|-----------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| Above Ceiling Inspection | Khanh Nguyen | Failed | Friday, July 26, 2013 |

Corrective Action Required
1 MISC

-COMPLETE INSTALLATION OF WATER HEATER (BOTH PLUMBING AND ELECTRICAL)
-ALL ABOVE CEILING PVC VENT LINES SHALL BE WRAPPED WITH LISTED WRAPPING. EXPOSED OSB SHEATHING AT NORTH SIDE OF BUILDING. EXPOSED MATERIAL IN PLENUM SHALL BE NON-COMBUSTIBLE OR SHALL HAVE A FLAME SPREAD INDEX OF NOT MORE THAN 25 AND SMOKE DEVELOPE INDEX OF NOT MORE THAN 50.

Comments: