

CODES ADMINISTRATION

Temporary Certificate of Occupancy

Permit #: PRCOM20121257

Address: 110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

Inspected On: Friday, July 26, 2013

Inspected By: John Borns

Expiration Date: 8/29/2013 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection: Outcome: Date:

Occupancy Inspection - John Borns Temporary C of O Friday, July 26, 2013

Codes Commercial

Corrective Action Required:

1 MISC ONLY SPACE 1F151A REMAINS TO BE APPROVED WHEN READY FOR

FINAL INSPECTION. MED GAS EXHAUST IS REQUIRED IN THIS SPACE

FOR INTENDED USE & OCCUPANCY.

TCO EXTENDED PENDING PROCUREMENT AND INSTALLATION OF E.F. ON ORDER BY JED.