



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20131202, Building Permit - Commercial  
Address: 1736 NW CHIPMAN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	John Borns	Partial	Monday, July 29, 2013

Corrective Action Required  
1 MISC

IPC 305.8; IRC P2603: SHIELD PLATES REQUIRED AT BASE PLATES / BOTTOM TRACKS AND TOP PLATES / TRACKS SHALL EXTEND A MINIMUM OF 2" ABOVE BASE PLATES / BOTTOM TRACKS AND BELOW TOP PLATES / TRACKS. CHECK ALL.

**Comments:**