



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20130305, Building Permit - Commercial  
Address: 10 NE TUDOR RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Electrical Inspection - Commercial</b>	John Borns	Partial	Tuesday, July 30, 2013

Partial Correction  
1 MISC

OK TO COVER WHEN READY UNDER-SLAB ELECTRICAL CONDUIT FROM (11) TO (13) ON ~(D.4);

<b>Underslab Electrical Inspection - Commercial</b>	John Borns	Partial	Tuesday, July 30, 2013
---	------------	---------	------------------------

Partial Correction  
1 MISC

OK TO COVER WHEN READY THREE 3" PVC SCH 40 UNDER-SLAB ELECTRICAL CONDUITS FROM (11) TO (13) ON ~(D.4);

**Comments:**