



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130027, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086 110 NE SAINT LUKES
BLVD, Unit:120, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for
re-inspection once all corrective actions have been completed. Do not cover any work until
approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Thursday, August 01, 2013

Partial Correction
5 MISC

**OK TO COVER WHEN READY TRENCHED PVC POWER AND
GROUNDING CONDUIT FROM W WALL OF BUNKER W TO/AT
LOCATION OF GATE.**

Comments: