

Temporary Certificate of Occupancy

Permit #: PRCOM20131297
Address: 5008 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064
Inspected On: Friday, August 02, 2013
Inspected By: Joe DirKhanh NguyenJoe DirKhanh Nguyen
Expiration Date: 9/2/2013 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Alarm Test	Joe Dir	Passed	Friday, August 02, 2013
Occupancy Inspection - Fire	Joe Dir	Temporary C of O	Friday, August 02, 2013

Corrective Action Required:

1 MISC address rear door with the numeric address of 5008
remove the 5012 from side door
mount (1) 2A-10BC fire extinguisher on a wall close to exit with top
of the extinguisher no higher than 60" from the floor

Occupancy Inspection - Codes Commercial	Khanh Nguyen	Temporary C of O	Friday, August 02, 2013
--	--------------	------------------	-------------------------

Corrective Action Required:

1 MISC -COMPLETE FIRE DEPARTMENT LIST
-COMPLETE DEDICATED 20 AMP CIRCUIT OF SIGNAGES
-POSTED NO-SMOKING SIGNAGE AT ENTRANCE

-INSTALL SIGNAGE FOR RESTROOMS