



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20131545, Building Permit - Commercial
Address: 200 NE MISSOURI RD, Unit:301, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Khanh Nguyen	Partial	Tuesday, August 06, 2013

Corrective Action Required

1 MISC

IN-WALL OK TO ROCK, EXCEPT AT THE RM 113 WALL WHERE SINK PLUMBING IS NOT COMPLETED.

Comments: