



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130791, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|----------|--------------------------|
| Underground Electrical Inspection - Commercial | John Borns | Partial | Tuesday, August 13, 2013 |

Partial Correction
1 MISC

OK TO COVER WHEN READY ONE 3" PVC UNDERGROUND CONDUIT FROM EAST RETAINING WALL TO NEW LOCATION OF LIGHTING CONTROLLER; PVC CONDUIT TO & IN THE AREA OF L.P.#5; 11; 15; 21; 25; [4; 5; 9; 10; 10*; 25;

Partial Correction
2 MISC

OK TO POUR WHEN READY CONCRETE LIGHT POLE BASE(S) AT FOLLOWING LOCATIONS: #4; 5; 9; 10a; 10b; 11; 15; 21; 25;

Partial Correction
4 MISC

OK TO COVER WHEN READY CONDUIT AND ENCLOSURES FOR SEVEN LUMINAIRES AT THE FOOT OF THE WEST FACE OF THE RETAINING WALL.

Comments: