



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRROOF20131029, Roofing Permit  
Address: 205 SW 3RD ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

|                                  |            |          |                            |
|----------------------------------|------------|----------|----------------------------|
| Inspection:                      | Inspector: | Outcome: | Date:                      |
| <b>Roof Final<br/>Inspection</b> | John Borns | Passed   | Wednesday, August 14, 2013 |

**Comments: WORK APPARENTLY COMPLETED. NO CODE VIOLATIONS FOUND ON REPLACEMENT OF ROOF COVERING WITH COMPOSITION SHINGLES. NO INSTALLER NOR MATERIAL INFORMATION ON SITE; MATERIAL APPROVAL BASIS LIMITED TO APPLICATION. CLOSE PERMIT.**