



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20131545, Building Permit - Commercial
Address: 200 NE MISSOURI RD, Unit:301, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Plumbing Inspection - Commercial	John Borns	Passed	Monday, August 19, 2013

CommentsNEW : PLUMBING AT SPACE [113]: C.I. DWV PIPING @ NE CORNER OK TO COVER WHEN READY. COPPER WATER PIPING @ SW CORNER OK TO COVER AFTER BEING SECURED AT BOTTOM.