



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20100314, Building Permit - Commercial
Address: 803 NE LAKEWOOD BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Plumbing Inspection - Commercial	Khanh Nguyen	Failed	Monday, December 27, 2010

Corrective Action Required

1 P501 GENERAL
WATER HEATERS

WATER HEATER P/T VALVE DISCHARGE SHALL:
-HAVE VISIBLE AIR GAP OR AIR GAP FITTING AND SHALL BE LOCATED IN THE SAME RM AS THE WATER HEATER.
-SHALL NOT CONNECT TO THE WASTE DRAINAGE SYSTEM AND SHALL DISCHARGE TO AN APPROVED SAFE PLACE OF DISPOSAL SUCH AS A FLOOR RECEPTOR OR AN APPROVED INDIRECT WASTE RECEPTOR

Comments: