



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20100137, Building Permit - Commercial
Address: 1255 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	John Borns	Not Ready	Tuesday, September 20, 2011

Corrective Action Required
2 MISC

REVISED ELECTRICAL DRAWING TO BE SUBMITTED AND
APPROVED

Water Service Inspection - Commercial	John Borns	Passed	Tuesday, September 20, 2011
--	------------	--------	-----------------------------

Underground Electrical Inspection - Commercial	John Borns	Passed	Tuesday, September 20, 2011
---	------------	--------	-----------------------------

Electrical Service Inspection - Commercial	Mike Copeland	Failed	Tuesday, September 20, 2011
---	---------------	--------	-----------------------------

Corrective Action Required
1 MISC

INSTALL BONDING BUSHINGS AT ALL SERVICE EQUIPMENT

Corrective Action Required
2

EQUIPMENT GROUND NOT INSTALLED AT 200 AND 400 AMP

SUB-PANELS.

INSTALL MAIN BONDING JUMPER SIZE IN ACCORDANCE WITH
800 AMP SERVICE PER NEC

EXPOSE CONCRETE ENCASED ELECTRODE.

Comments: