



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20131819, Building Permit - Commercial
Address: 224 SE DOUGLAS ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - Commercial	John Borns	Partial	Wednesday, August 21, 2013

Partial Correction

1 MISC

OK TO COVER WHEN READY WATER SERVICE LINE
CONNECTION UNDER SIDEWALK FOR 224 SE DOUGLAS ST
TIGHTED TO ELIMINATE LEAK; TO BE PROTECTED FROM ST
LINE ABOVE

Comments: