



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130305, Building Permit - Commercial
Address: 10 NE TUDOR RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Partial	Wednesday, August 21, 2013

Partial Correction

1 MISC

OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING AT FOLLOWING LOCATIONS: (K.9) TO (N.1) x (5.6) TO (6.2); 6" PVC ST & 4" PVC SAN PER PR-02 FROM F.5/12.3 N & OFFSET TO F.4 5' OUTSIDE B/L; **AREA B AND LOWER LIFT @ AREA C PER PR#2 MODIFICATIONS;**

NOTE IPC 312 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.

Comments: