



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20131202, Building Permit - Commercial
Address: 1736 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Monday, August 26, 2013

Corrective Action Required
2 MISC

ROOFTOP INSPECTION:

- 3) GAS PIPE SUPPORT BLOCK SLIP SHEETS MUST BE FASTENED TO SIDES OR ENDS OF BLOCKS
- 4) CLOTHES DRYER VENT STACK NOT TERMINATED OR FLASHED

Corrective Action Required
9 MISC

IMC 507.16 COMMERCIAL KITCHEN GREASE HOOD PERFORMANCE TEST: NEBBS-CERTIFIED REPORT REQUIRED TO BE SUBMITTED TO INSPECTOR WHEN EQUIPMENT IS OPERATIONAL AND BEFORE COMMERCIAL USE

Comments: