

CITY OF LEE'S SUMMIT CODES ADMINISTRATION 220 SE GREEN ST. P.O.BOX 1600

PHONE: 816-969-1200

FAX:

816-969-1201

Inspection Summary

Permit #: PRCOM20130393, Building Permit - Commercial Address: 194 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Underslab Electrical John Borns

Inspection -Commercial Passed Tuesday, August 27, 2013

Underslab Plumbing John Borns

Inspection -Commercial Passed

Tuesday, August 27, 2013

Water Service

Commerciall

John Borns Inspection -

Partial

Tuesday, August 27, 2013

Partial Correction

MISC 1

OK TO COVER WHEN READY DOMESTIC WATER SERVICE LINE FROM BUILDING ENTRY TO 15' WEST. COPPER OR PEX OK

EXCEPT FIRST 10' FROM METER MUST BE COPPER.

Comments: