



PLANS REVIEW CONDITIONS

Permit No: PRCOM20130740 Date: August 23, 2013
Project Title: LEES SUMMIT MEDICAL CENTER Applicant: Siemens Industry, Inc.
NEUROLOGY SUITE 8066 Flint Street
Location: 2100 SE BLUE PKWY, Lenexa , KS 66214
LEES SUMMIT, MO 64063
Type of Work: Primary: (913) 492-3040
Occupancy Group: B
Description: PHASED REMODEL
Construction Type: Type IIB (Unprotected)
Map Page: 196k

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Brian Austerman

Released for Construction

1. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule alarm testing

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.