



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20131231	Date:	August 22, 2013
Project Title:	INSTANT AUTO	Applicant:	ALPHA FIRE PROTECTION
Location:	2151 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064		P.O. BOX 50 INDEPENDENCE, MO 64056--1783
Type of Work:			
Occupancy Group:	B	Primary:	(816) 257-2260
Description:	AUTO DEALERSHIP		
Construction Type:	Type IIB (Unprotected)		
Map Page:	175U		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Brian Austerman

Released for Construction

1. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule hydrostatic and flow testing in conjunction with alarm testing prior to final

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.