



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20100137, Building Permit - Commercial
Address: 1255 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Monday, July 11, 2011

Partial Correction
2 MISC

7/11/11 REQUEST FOR INSPECTION OF SITE ELECTRICAL
BURIED CONDUIT: ALL CONDUIT EXCEPT THAT FOR SERVICE
SECONDARY AND FOR MONUMENT SIGN OK TO COVER WHEN
READY

Underground Electrical Inspection - Commercial	John Borns	Not Ready	Monday, July 11, 2011
---------------------------------------------------------------	------------	-----------	-----------------------

Partial Correction
1 E300.5 Underground
Installations

1. PARTIAL -UNDER DRIVEWAY/FRONT STREET ONLY-FROM
OUT SIDE CURB TO CURB
1" TO SUMP PUMP
1" TO MONUMENT SIGN

Corrective Action Required
2 MISC

7/11/11 REQUEST FOR INSPECTION OF SITE ELECTRICAL
BURIED CONDUIT: CONDUIT NOT COMPLETELY LAID IN TRENCH

Comments: