



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20115978, Building Permit - Commercial

Address: 806 SW BLUE PKWY, LEES SUMMIT, MO 64063818 SW BLUE PKWY, LEES SUMMIT, MO 64063820 SW BLUE PKWY, LEES SUMMIT, MO 64063822 SW BLUE PKWY, LEES SUMMIT, MO 64063824 SW BLUE PKWY, LEES SUMMIT, MO 64063826 SW BLUE PKWY, LEES SUMMIT, MO 64063828 SW BLUE PKWY, LEES SUMMIT, MO 64063834 SW BLUE PKWY, LEES SUMMIT, MO 64063838 SW BLUE PKWY, LEES SUMMIT, MO 64063840 SW BLUE PKWY, LEES SUMMIT, MO 64063846 SW BLUE PKWY, LEES SUMMIT, MO 64063848 SW BLUE PKWY, LEES SUMMIT, MO 64063852 SW BLUE PKWY, LEES SUMMIT, MO 64063856 SW BLUE PKWY, LEES SUMMIT, MO 64063858 SW BLUE PKWY, LEES SUMMIT, MO 64063862 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Electrical Inspection - Commercial	John Borns	Passed	Monday, January 16, 2012

Corrective Action Required
1 MISC

WOOD BLOCK CONDUIT SUPPORTS IN DIRECT CONTACT WITH ROOF; SLIPSHEETS REQUIRED UNLESS ROOF COVERING WARRANTY ALLOWS CONTACT AS-IS.

Comments: