



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20116192, Building Permit - Commercial
Address: 653 SW 2ND ST, LEES SUMMIT, MO 64063651 SW 2ND ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Not Ready	Thursday, January 12, 2012

Corrective Action Required
1 MISC

PARTIAL IN-WALL INSPECTION TO BE PERFORMED WHEN ACCESSIBLE

Occupancy Inspection - Fire	Joe Dir	Temporary C of O	Thursday, January 12, 2012
------------------------------------	---------	------------------	----------------------------

Corrective Action Required
1 MISC

- (1) label all front and back doors with the same address (653)
- (2) supply (3) 2A-10BC extinguishers and mount in the locations as discussed
- (3) remove slide bolt locks from the rear doors and repair panic hardware
- (4) post an occupant load of (124) in the sanctuary

Comments: