



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20130305, Building Permit - Commercial  
Address: 10 NE TUDOR RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection - Commercial</b>	John Borns	Partial	Wednesday, August 28, 2013

Partial Correction  
1 MISC

OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING AT FOLLOWING LOCATIONS: (K.9) TO (N.1) x (5.6) TO (6.2); 6" PVC ST & 4" PVC SAN PER PR-02 FROM F.5/12.3 N & OFFSET TO F.4 5' OUTSIDE B/L; AREA B AND LOWER LIFT @ AREA C PER PR#2 MODIFICATIONS; **PIPING FROM TRENCH DRAIN + COMPLETION OF PIPING AT SAND INTERCEPTOR THEN SAN + STORM THRU N WALL FOOTING;**

NOTE IPC 312 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.

<b>Underslab Electrical Inspection - Commercial</b>	John Borns	Partial	Wednesday, August 28, 2013
---	------------	---------	----------------------------

Partial Correction  
1 MISC

NO ISSUES FOUND ON UNDER-SLAB ELECTRICAL CONDUIT MATERIAL & WORKMANSHIP. OK TO COVER WHEN READY AT: AREA A; **AREA B FROM (E)TO(L.8)x(7.1)TO13); [111] & [108];**

**Comments:**

