

City of Lee's Summit

Applicant's Letter

220 SE Green Street
Lee's Summit, Missouri 64063
(816) 969-1600 Fax (816) 969-1619

Fireworks Permit

Date: Monday, April 30, 2012

Application Number: PRFW20120776

To:

SKY BLOOMS FIREWORKS

<NO FAX NUMBER>

CP DEER BROOK PLAZA
LLC

<NO FAX NUMBER>

COLDWATER OF LEE'S
SUMMIT

<NO FAX NUMBER>

<NO CONTACT NAME
AVAILABLE>

<NO FAX NUMBER>

From: Hector Soto, Planner

RE: PRFW20120776,
Applicant: COLDWATER OF LEE'S SUMMIT, Address:501 NE MISSOURI RD

Address: 1125 NE RICE RD, LEES SUMMIT, MO 64086

Conditions:

Building Codes Review (FW)	Mike Copeland	Manager of Building Inspections	(816) 969-1204	Pending
Fire Codes Review (FW)	Jim Eden	Assistant Chief	(816) 969-1303	Approved

1. Seasonal tents shall not be located within 50 feet of any gasoline pump, gasoline filling station, gasoline bulk station, or any building in which gasoline or volatile liquids are sold in quantities in excess of one gallon.

For information only.

2. The set-up and use of a Seasonal Retail Fireworks Tent shall comply with the Chapter 13 - Fire Prevention and Protection, of the Code of Ordinances of the City of Lee's Summit, Article III Fire Code, Section 13-44 Same Amendments, and Missouri 11 CSR 40-3 -Fireworks.

All tents will receive an initial site inspection before being allowed to stock, and a second inspection of product before being allowed to open to the public.

Planning Review (FW)	Hector Soto	Planner	(816) 969-1604	Corrections
-----------------------------	--------------------	----------------	----------------	--------------------

1. SIGNAGE. Provide additional detail for the required tent signage.
 - Each tent is required to have at least one 32 sq. ft. banner reciting the identity of the licensee not-for-profit. The sign shall be placed in a highly visible location.
 - A sign at least 12" x 12" in size reciting the identity of the licensee not-for-profit shall also be placed near the cash register area(s).