

CITY OF LEE'S SUMMIT CODES ADMINISTRATION 220 SE GREEN ST. P.O.BOX 1600

PHONE: 816-969-1200

FAX: 816-969-1201

Temporary Certificate of Occupancy

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Thursday, December 06, 2012
Corrective Action Required:			
1 MISC	RESOLVE FIRE DEPARTMENT ISSUES		
Corrective Action Required:			
2 MISC	NEC 370-20; IRC E3806.5-6 SET-BACK OF ELECTRICAL		
	RECEPTACLE / SWITCH BOXES: 1/4" MAXIMUM SET-BACK @		
	NON-COMBUSTIBLE SURFACES SEE AT HARD TILE WALLS		
	IN RESTROOMS.		

Comments: