



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20131173, Building Permit - Commercial
Address: 1900 NE LANGSFORD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Thursday, August 29, 2013

Partial Correction
1 MISC

OK TO COVER WHEN READY ACT CEILING FRAMING +
ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: 112
EXCEPT LEAVE OUT 2 TILES FOR*; 113;

*: SECURE FLOATING J-BOX TO STRUCTURE; SECURE FLEX TO
WALL WITHIN 12" OF BOX

**Comments: NO ISSUES FOUND IN WORK AREA 2' OUTSIDE PERIMETER WALLS OF 112
& 113**