

CITY OF LEE'S SUMMIT

PUBLIC WORKS DEPARTMENT / INSPECTIONS DIVISION 220 SE Green Street LEE'S SUMMIT, MISSOURI 64063

(816) 969-1800 FAX (816) 969-1810

PUNCH LIST

August 04, 2012

Re Certificate of Substantial Completion for:

PWorks Commercial, Development-Public Works EN2010-036

A comprehensive inspection was completed for this project. It has been determined by Public Works that a Certificate of Substantial Completion can be released. The following items were incomplete as of the date of this letter. The developer, contractors and engineers have ninety (90) days to complete these deficiencies in accordance with the City of Lee's Summit's, Design and Construction Manual, Ordinance 5813. Failure to complete all items will result in a freeze of building permits until all items are corrected and a Certificate of Final Acceptance is issued.

PUNCH LIST CORRECTIONS:

Subgrade Inspection

Failed

1

The general contractor Straub Construction will have get an Engineering revision on the adjustment of the north concrete drive entrance from Cook, Flat, and Strobel. The correction will raise the percent of grade for the concrete drive to 3.5% instead of 7%. 7% grade will put the new 24"RCP storm pipe in the new 7" concrete slab.

, Developer (Signature & Date)

Bill Lyon, Public Works Inspector (Signature & Date)

Original: Public Works Inspector

Copy: PW Records Tech

PW Inspections Supervisor

GIS Manager

File

Financial Analyst PW Eng. Review Manager

Pw Eng. Review Manager Public Works Operations

Contractor

Codes Admin.

Codes Admin. Manger Water Operations

Engineer



[&]quot;An American Public Works Association Accredited Public Works Department"