

Temporary Certificate of Occupancy

Permit #: PRCOM20121257
Address: 110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086
Inspected On: Thursday, August 29, 2013
Inspected By: John BornsJoe Dir
Expiration Date: 9/19/2013 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Thursday, August 29, 2013

Partial Correction:

1	MISC	ONLY SPACE 1F151A REMAINS TO BE APPROVED WHEN READY FOR FINAL INSPECTION. MED GAS EXHAUST IS REQUIRED IN THIS SPACE FOR INTENDED USE & OCCUPANCY. 8/29/13: PER FD, DUCT MUST BE PROTECTED BEFORE APPROVAL.
---	------	---

Occupancy Inspection - Fire	Joe Dir	Temporary C of O	Thursday, August 29, 2013
------------------------------------	---------	------------------	---------------------------

Corrective Action Required:

1	MISC	Oxygen back-up room (1F151A) for 4th floor ICU
---	------	--

-exhaust for the room needs to be enclosed in 1-hour protection from the room until it exits the building

- property owner to verify that all the red outlets and switches supply power during a generator test.

TCO EXTENDED TO ACCOMODATE RESOLUTION OF ABOVE ISSUES.