

Temporary Certificate of Occupancy

Permit #: PRCOM20130027
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086
LUKES BLVD, Unit:120, LEES SUMMIT, MO 64086
Inspected On: Thursday, August 29, 2013
Inspected By: John BornsJoe DirJohn BornsJohn BornsJohn BornsJohn BornsJohn
BornJoe Dir
Expiration Date: 9/26/2013 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Thursday, August 29, 2013

Corrective Action Required:

1 MISC RESOLVE FIRE DEPARTMENT ISSUES

Partial Correction:

2 MISC **UROLOGY DEPARTMENT AREA OK FOR OCCUPANCY**

**ONCOLOGY/RADIATION DEPARTMENT AREA OK TO SET UP FOR
BUSINESS. NO PATIENTS PRIOR TO APPROVAL.**

**ALL EMERGENCY CIRCUITS MUST BE TESTED ON GENERATOR
POWER AND CERTIFIED OPERATIONAL.**

Alarm Test	Joe Dir	Passed	Thursday, August 29,
-------------------	---------	--------	----------------------

2013

Corrective Action Required:

- 1 MISC - all card readers need to drop off on alarm activation, corridors, stairways, passage doors
- mag hold open doors need to drop off on alarm activation, come fully closed
- on the silence command from the facp - both horns and strobes need to terminate.
- new panel check dial out and addressing of panel

Underslab Electrical Inspection - Commercial	John Borns	Passed	Thursday, August 29, 2013
---	------------	--------	---------------------------

Rated Assembly Inspection	John Borns	Passed	Thursday, August 29, 2013
----------------------------------	------------	--------	---------------------------

Rough Framing Inspection - Commercial	John Borns	Passed	Thursday, August 29, 2013
--	------------	--------	---------------------------

In-wall Inspection	John Borns	Passed	Thursday, August 29, 2013
---------------------------	------------	--------	---------------------------

Underground Electrical Inspection - Commercial	John Borns	Passed	Thursday, August 29, 2013
---	------------	--------	---------------------------

Occupancy Inspection - Fire	Joe Dir	Temporary C of O	Thursday, August 29, 2013
------------------------------------	---------	------------------	---------------------------

Corrective Action Required:

- 1 MISC Urology area appeared appropriate at the time of the inspection.
- Oncology/Radiation: OK to set up for patients, no patient treatment until LINACs fail safes are all tested
- north security gate, keys and or combination for access needed to

be placed in knox box.

- bldg owners to verify that all red outlets and switches supply power during generator tests.