



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20131638, Building Permit - Commercial
Address: 840 NW BLUE PKWY, Unit:J, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Friday, August 30, 2013

Partial Correction
1 MISC

FIRE-TREATED PLYWOOD OK TO COVER WHEN READY AT
NORTH DEMISING WALL PER DRAWING AFTER ALL SHEETS ARE
FULLY NAILED PER DRAWING

Comments: