



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20131173, Building Permit - Commercial  
Address: 1900 NE LANGSFORD RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Khanh Nguyen	Failed	Tuesday, September 03, 2013

Corrective Action Required  
1 MISC

\*THE BUILDER IS NOT ON SITE. CAPTAIN DIR CALLED HIM BUT RECEIVED NO ANSWER. RESCHEDULE FOR ANOTHER INSPECTION  
\*NOTE OF THE FOLLOWING: THE INSTANT WATER HEATER IS RATED AT 120 V & 30 AMP(?). THE CIRCUITS THAT SERVE THESE HEATERS SHALL BE SIZED ACCORDINGLY. #10 COPPER CIRCUIT SHALL BE REQUIRED AND VERIFIED

**Comments:**  
DO NOT OCCUPY THE EXAM ROOMS