

## CITY OF LEE'S SUMMIT CODES ADMINISTRATION 220 SE GREEN ST. P.O.BOX 1600

PHONE: 816-969-1200

FAX:

816-969-1201

## **Inspection Summary**

Permit #: PRRES20130943, Building Permit - Residential

Address: 2050 SW COUNTY LINE RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection -Residential Mark Harding

Failed

Tuesday, September 03, 2013

Corrective Action Required

1 MISC

- 1. NAIL DBL TRUSS PER PLANS
- 2. INSTALL BRACED WALLS PER PLANS
- 3. INSTALL HURRICANE STRAPS 2ND FLOOR , FRON MSTR, ALL EXTERIO BEARING TRUSS
- 4. FIRESTOP MSTR TUB, INSTALL MSTR TUB, SOLID BLOCK REAR 2ST FLOOR CHASE BACK WALL. BUILD REAR N.E. CHASE GREAT ROOM, FIRESTOP LANDING FROM WALL,
- 5.ANCOR BSMT BEAM POST, ANCOR GARAGAE BEAM POST.
- 6. INSTALL GAS LINE
- 7. SUPPORT 2X10 AT STAIR WALL NEXT TO LVL
- 8. SUPPORT ALL LVL AND BEARING POINT WITH CORRECT NUMBER OF STUDS AS PER PLANS, BREAKFAST NOOK, DINNING ETC.
- 9. INSTALL DBL JOIST BSMT AS PER PLANS
- 10. FIRESTOP HEAT CHASE REAR CENTER BEDROOM CLOSET CHASE
- 11. SUPPORT DWV 48" OC.C, SUPPORT PEX PIPING IN WALL AT 36".
- 12.FLUE CLEARANCE TO PEX AND ROMEX.
- 13. GARAGE DOOR STRAPS
- 14. ROMEX 6' ATTICE ACCESS-PROTECT
- 15. JOIST HANGER NAILS 1ST FLOOR OVER BENCH HALL-DO NOT COVER

Electrical Service Ma Inspection -Residential

Mark Harding Passed

Tuesday, September 03, 2013

Comments: